



# Compliance Statement

## Screened Category 6 ISO/IEC, EN & TIA/EIA Communication Cable

**R&M Identification R308247**

**Category 6, Individual Foil Screened without Overall Screen  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LS0H, Copper Cable**

**Reichle & De-Massari AG  
Binzstrasse 31  
CHE-8622 Wetzikon, Switzerland**

*Compliance Statement No. 104305D*

*This Screened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1, ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1 (modified to cover individual foil screened cables), IEC Cable Standard 61156-5, and the requirements of CENELEC Cable Standard EN 50288-5-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 20 February 2008

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 20 February 2008

*Paul Villien*

Poul Villien  
Coordinating Manager