



# Compliance Statement

## Screened Category 5<sup>+</sup> (Cat. 5e) ISO/IEC, EN & TIA/EIA Communication Cable

### R&M Identification R35053

Category 5<sup>+</sup> (Cat. 5e), Overall Foil and Braid Screened  
100  $\Omega$ , 4 Twisted Pairs, 24 AWG, Fire Retardant, LSFR0H, Copper Cable

**Reichle & De-Massari AG**  
**Binzstrasse 31**  
**CHE-8622 Wetzikon, Switzerland**

### *Compliance Statement No. 98162I*

*This Screened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5:2002 performance requirements of the 2nd edition ISO/IEC Generic Cabling Standard 11801 and CENELEC Generic Cabling Standard EN 50173-1, the Category 5e requirements of ANSI/TIA/EIA Generic Cabling Standard 568-B.2 (modified for presence of overall foil and braid screening) and IEC Cable Standard 61156-5, and the requirements of the 2nd edition CENELEC Cable Standard EN 50288-2-1. Fire Retardancy is verified according to IEC 60332-3, Cat. C:1992. The cable has EMC Performance Rating 10. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 months intervals.*

Hoersholm, 27 January 2006

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 27 January 2006

*Paul Villien*

Poul Villien  
Coordinating Manager