



Attestation of Conformity

Unscreened Category 6 CENELEC Connecting Hardware

R&M Identification R302373 / R305072

Category 6, Unscreened, Mated Connecting Hardware
Electrical Transmission Performance

Reichle & De-Massari AG
Binzstrasse 31
CH-8622 Wetzikon, Switzerland

Attestation of Conformity No. 101152

This unscreened RJ 45 mated connecting hardware consisting of Jack type R302373 and Plug type R305072 has been tested by 3P Third Party Testing and complies with the Category 6 connecting hardware requirements of the draft 2nd Edition of CENELEC EN 50173 and Category 5 requirements of CENELEC EN 50173/A1 . The Attestation of Conformity is valid for the actually tested connecting hardware sample and no verification of the running production has been performed.

Hoersholm, 21 June 2001

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 21 June 2001

Paul Villien

Poul Villien
Coordinating Manager