



# Attestation of Conformity

## Unscreened Category 6<sub>A</sub> ISO/IEC, EN & TIA Connecting Hardware

**Reichle & De-Massari Identifications**

**P/N R509500, R509501, R509502, R509503, R509508 and R510087**

**Category 6<sub>A</sub>, Unscreened, Modular Jack  
Electrical Transmission Performance**

**Reichle & De-Massari AG**

**Binzstrasse 31**

**CH-8622 Wetzikon, Switzerland**

**Attestation of Conformity No. 110726A**

*This Unscreened ISO/IEC, CENELEC & TIA Connecting Hardware having board identification "16-0163 TL" has been tested by 3P Third Party Testing and complies with the Category 6<sub>A</sub> transmission requirements of Amendment 2 to 2<sup>nd</sup> edition ISO/IEC Generic Cabling Standard 11801, Amendment 2 to CENELEC EN 50173-1 (draft FprAB July 2010) and IEC Connecting Hardware Standard 60603-7-41, Category 6A transmission requirements of ANSI/TIA Generic Cabling Standard 568-C.2, and IEC test standard 60512-27-100 (draft 48B/2060/CD). The requirements are passed for both sides of the modular jack using the complete specified re-embedded range of RJ 45 plug vectors. The Attestation of Conformity is valid for the actually tested connecting hardware samples and no verification of the running production is performed.*

Hoersholm, 10<sup>th</sup> December 2010

Hoersholm, 10<sup>th</sup> December 2010

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

*Paul Villien*

Poul Villien  
Coordinating Manager